

# ORION

SABS  
ISO 9001

CE  
0402



## Inland Regions (Powered)

One off electrically operated smoke and heat exhaust dual-purpose ventilator manufactured from (galvanised [or] chromadek [or] zincalume [or] colour plus) material, complete with a failsafe (24V DC power to open and power to close actuator). Each ventilator shall be fitted with a back-up fusible link system selected to activate at (74°C; 100°C; 138°C; 182°C & 232°C). The ventilator shall have an  $A_v C_v$  of  $x.xx \text{ m}^2$ . The ventilator is required to span a purlin spacing of  $xxxx \text{ mm}$ , or “H-Frames” shall be included at an additional cost. The ventilator shall be certified EN 12101:2 compliant with the minimum test results achieved: WL (1700); SL (0); T(00); Re (100) and B300.

For a quote or more information contact us:



+27 11 608 4640



info@rvi-group.com



www.rvi-group.com

01/17

# RVI

SMOKE VENTILATION